



NUMBER: V90/12
EXPIRY DATE: 31 DEC 1991

CERTIFICATE OF ACCREDITATION

WHEREAS Monolite Construction Panels Pty. Ltd.
of 129 Northern Road, West Heidelberg 3084
has applied to the Building Control Accreditation Authority for the accreditation of the
Monolite 130mm thick sprayed reinforced concrete loadbearing external
cladding or internal partitioning sandwich panel system

the Building Control Accreditation Authority appointed under Part V of the Building Control Act 1981
has examined the application and determines that the system may be used in buildings
containing up to 2 storeys (maximum storey height of 4 metres) except
those having special post-disaster functions as per AS 1170 Pt. 2 and
complies with the requirements of Regulation(s) 40.1 (1), 43.1 (1) and 47.1 (2)
of the Victoria Building Regulations 1983.

Conditions of use and identification details are provided in the ten (10) data sheet(s) attached.



BUILDING CONTROL
ACCREDITATION AUTHORITY
VICTORIA

C. McBurney

DATE

7 DECEMBER 1990

REGISTRAR